



NOTES:
 1. ALL EXTINGUISHERS AND MOUNTING HARDWARE SHALL BE REUSED FROM ORIGINAL INSTALLATION.
 2. ALL EXTINGUISHER MOUNTING BRACKETS SHALL BE POSITIONED SUCH THAT THEIR HORIZONTALLY PROJECTING COMPONENT IS AT A HEIGHT OF 3'-0" ABOVE FINISHED FLOOR.

- LEGEND**
- W - H2O FIRE EXTINGUISHER 2 1/2 GAL., 2A RATING
 - D - ABC DRY CHEMICAL FIRE EXTINGUISHER, 2 1/2 LB. RATING, 1A108C MODEL AMEREX A417, S/N0007042
 - F - FOAM FIRE EXTINGUISHER 2 1/2 GAL., 3A-20B RATING, MODEL AMEREX 252, S/N0024721
 - C1 - CO2 FIRE EXTINGUISHER 5 LB., 5B RATING, MODEL AMEREX 322, S/N0007040
 - C2 - CO2 FIRE EXTINGUISHER 15 LB., 10B-C RATING, MODEL ANSUL, SY-1571, S/N0015524

NORTH
FIRST FLOOR FIRE EXTINGUISHER PLAN
 SCALE: 3/16"=1'-0"
 0 4 8 12